

This exercise is intended to support your self-directed learning.

Start by reading SPM Section I- 4 of Volume 1 for an overview of the new layout.

*You may wish to work with the digital version of the SPM, available at the following link:
<http://owrp.asttbc.org/p/documents.php>*

The 'paper' versions have a separate table of contents at the beginning of each of the four volumes. The digital version has those, plus a single table of contents covering all four volumes. The digital version table of contents have a 'click and go' feature, and it's helpful to use the 'Find' or 'Search' features.

To complete the exercise, first answer the questions, and then check the answer key - which is available at the SPM Learning Resources page: (<http://owrp.asttbc.org/p/resources.php>)

1. Which volume of the SPM contains the glossary?
 - a) I
 - b) II
 - c) III
 - d) IV

2. Which volume of the SPM contains the guidelines?
 - a) I
 - b) II
 - c) III
 - d) IV

3. Which volume of the SPM contains the standards?
 - a) I
 - b) II
 - c) III
 - d) IV

4. Which volume of the SPM contains the rationale, references and a listing of design manuals?
 - a) I
 - b) II
 - c) III
 - d) IV

5. What is the section identifier for vertical separation standards?
 - a) 2 - 5
 - b) II- 5.3
 - c) IV- 5.8
 - d) 3.4.1.1
 - e) I- 4.4.1

6. What is the section identifier for vertical separation guidelines?
 - a) I- 4.4.1
 - b) IV- 5.8
 - c) 2 - 5
 - d) II- 5.3
 - e) III- 5.3

7. Which pair of section identifiers correspond to standards and guidelines for specification and installation standards?
 - a) I- 4.4.1 and III- 3.6.1
 - b) II- 6 and III- 6
 - c) IV- 6 and II- 5.5
 - d) II- 3.6 and II- 4.2

8. Which section contains standards for tank installation?
 - a) II- 6.4
 - b) Table II- 35
 - c) III- 6.4.1.1
 - d) IV- 5.9.3 page IV- 22

9. Which section contains guidelines for watertight testing of tanks, including additional detail about procedures, alternative approaches and supporting information?
 - a) II- 6.4
 - b) Table II- 19
 - c) III- 6.4.3.2
 - d) IV- 5.9 page IV- 21

10. What is the section identifier for flow monitoring standards?
 - a) I- 4.4.1
 - b) 2 - 6
 - c) 2.4.2
 - d) II- 6.1

11. What is the section identifier for flow monitoring guidelines?
 - a) I- 3.4
 - b) IV- 6
 - c) 4 - 6
 - d) III- 6.1

12. What is the minimum required horizontal separation distance from a septic tank to a below ground water supply cistern?
 - a) 3 m
 - b) 7.5 m
 - c) 15 m
 - d) 30 m

13. What is the minimum required horizontal separation distance from a septic tank to a lake?
 - a) 7.5 m
 - b) 10 m
 - c) 15 m
 - d) 30 m

14. What is the minimum required horizontal separation distance from a BC zero discharge lagoon to an irrigation well?
- 3 m
 - 7.5 m
 - 15 m
 - 30 m
15. From the Sewerage System Regulation, what is the required setback from a septic tank or pump chamber to a drinking water well?
- 3 m
 - 7.5 m
 - 15 m
 - 30 m
16. For repair of an existing system, which of the following procedures requires a Filing submission to the Health Authority?
- replacement of transducer
 - installation of new tank risers and lids
 - extending trenches for additional area of infiltrative surface
 - replacement of short sections of pipe when not functioning as intended
17. For repair of an existing system, which of the following procedures does not require a Filing submission to the Health Authority?
- replacement of D-box
 - retrofitting treatment devices
 - addition of grease interceptor
 - upgrading trickle gravity to a pump to D-box configuration
18. Which section contains standards for the specification of trench infiltration systems?
- III- 6.4
 - II- 6.6
 - Table II- 36
 - III- 6.4.3.2
19. What is the trench width specification standard for a dispersal system on slopes greater than 15%?
- 1.83 m (183 cm)
 - less than 90 cm
 - 30 to 60 cm
 - 30 to 90 cm
20. Which table contains specification and installation standards for bed dispersal systems?
- Table II- 22
 - Table II- 32
 - Table II- 35
 - Table II- 38
21. What is the sand media specification standard for mound sand effective particle size (D_{10})?
- < 4% passing the No. 100 sieve
 - 1/16 mm to 2 mm
 - >0.25 mm
 - <0.3 mm

22. What is the minimum required residual pressure (squirt height) when using 3.2 mm (1/8 inch) orifices
- 60 cm
 - 90 cm
 - 150 cm
 - 180 cm
23. What is the minimum required depth of drain rock under the distribution piping for a sand mound?
- 2.5 cm
 - 10 cm
 - 15 cm
 - 23 cm
24. What is the required soil texture classification for cover soil of sand lined trenches?
- loam or sandy loam
 - permeable native soil
 - loamy sand, loamy fine sand or sandy loam
 - clean course sand, mound sand or sand filter coarse sand
25. For gravelless infiltration systems what is the requirement for observation ports?
- one on each lateral
 - at least two per drainfield
 - two on each lateral, distal and proximal
 - ports are not required for gravelless systems
26. What is the maximum allowable width of a seepage bed?
- 0.9 m
 - 1.8 m
 - 3.0 m
 - 3.6 m
27. What is the minimum vertical separation in native soil for gravity distribution when the percolation rate is 0.5 minutes per inch?
- 60 cm
 - 90 cm
 - 150 cm
 - 183 cm
28. For sandy loam, what is the minimum required Vertical Separation (VS) in native soil for uniform distribution of type 1 effluent with low frequency demand dosing?
- 45 cm
 - 60 cm
 - 70 cm
 - 75 cm
29. Determine the minimum required VS, given the following conditions:
- uniform distribution
 - demand dosing
 - dose frequency of 6 times per day based on DDF
 - type 2 effluent, type 2 HLR
 - soil texture is loamy sand at the infiltrative surface and at least 30 cm below

The minimum required VS in native soil is _____ (fill in the blank).

30. Determine the minimum required VS, given the following conditions:
- uniform distribution
 - timed dosing
 - dose frequency of 10 times per day based on DDF
 - type 1 effluent, type 1 HLR
 - soil texture is loamy sand at the infiltrative surface and at least 30 cm below

The minimum required VS in native soil is _____
and the minimum as constructed VS is _____ (fill in the blanks).

31. Determine the minimum required VS, given the following conditions:
- uniform distribution
 - demand dosing
 - dose frequency of 14 times per day based on DDF
 - type 2 HLR
 - soil texture is loamy sand at the infiltrative surface and at least 30 cm below
 - sand media will not be used ... is not a practical option due to high transport costs

The minimum required VS is _____.

32. The depth of permeable, unsaturated soil within a proposed dispersal area is 180 cm. Soil texture is loamy sand. What is the maximum depth from surface to trench bottom (i.e. how deep can the trench be) that will achieve VS standards for gravity dispersal trenches?

33. The native soil has a texture of loam, with 90 cm depth to a restrictive layer of clay loam. A type 1 pressure dispersal system is proposed, with demand dosing at 4 doses per day. What is the required elevation relative to original grade of the infiltrative surface (i.e. how deep?), to meet the minimum VS standards?

34. The depth of suitable soil is 35 cm. A type 1 sand mound with timed dosing is proposed. Dose volume will be 1/12 th of DDF. What is the required elevation relative to original grade of the infiltrative surface, to meet the minimum VS standards?

35. What is the minimum DDF for a 3 bedroom residence with 280 m² of living area?

36. What is the minimum DDF for a 5 bedroom residence with 400 m² and with anticipated occupancy of 8 persons?
37. What is the minimum DDF for a sewerage system that will serve a 2 bedroom residence with 200 m² of living area and a secondary suite within a detached garage that has 1 bedroom and 55 m² of living area? Projected occupancy is 3 persons in the 2 bedroom primary residence and 2 persons in the 1 bedroom secondary residence.
38. What is the minimum DDF for a 90 m² cabin with an open floor plan (no bedrooms) used for approximately 60 days per year by 5 persons?
39. Is gravity dispersal allowed when the soil percolation rate is 20 seconds per inch?
- a) YES
 - b) NO
 - c) OK if dosed gravity is used (pump to D-box)
 - d) OK only if land slope is less than 15% in the dispersal area
40. Is gravity dispersal allowed when the system has more than 10 cm of sand media under the infiltrative surface?
- a) YES
 - b) NO
 - c) OK if dosed gravity is used (pump to D-box)
 - d) OK only if land slope is less than 15% in the dispersal area
41. Is gravity dispersal allowed when the system has more than 100 m² of infiltrative surface?
- a) YES
 - b) NO
 - c) OK if dosed gravity is used (pump to D-box)
 - d) OK only if land slope is less than 15% in the dispersal area
42. Is an Alberta At Grade System allowed if the site is not forested?
- a) YES
 - b) NO
 - c) OK if type 2 effluent is used
 - d) OK if land slope is less than 15% in the dispersal area
43. Which requirements are applicable (in addition to other standards) for dispersal to gravelly sand with perc rate faster than 0.5 minutes per inch?
- a) VS at least 183 cm
 - b) gravity dispersal must use pump to D-box
 - c) demand dosing with at least 8 doses per day
 - d) uniform distribution with timed or micro dosing

For questions 44 to 47, refer to III- 3.6 Installation. The 'questions' are direct quotes from the SPM. Fill in the blanks with the SPM text.

44. Prior to or during installation, the SSR requires that if any _____ are made to the information filed, the AP must _____ with the Health Authority to update the filing.
45. Changes significant enough to require filing an amendment include ... _____ of the dispersal system to a different area ... changes to the system design that result in _____ standards (e.g. a _____ that does not meet the minimum standard).
46. At system commissioning, it is critical to _____.
47. After installation, the installer should provide the filing AP with ... record of the installation including _____ ...an Installers _____ ... a _____ showing all measurements and locations for system components (_____ by the filing AP). These should be provided within _____ of completion of the installation.

For the remaining portion of the exercise (question 48 to 65), refer to III- 6 Specification and Installation Guidelines. The 'questions' are direct quotes from the SPM. Fill in the blanks with the SPM text.

48. Suitable access provisions will include risers or access boxes with _____, and with adjacent ground sloped to _____.
49. Pump control panels should be located in _____ or in a service building that will be accessible to the maintenance provider, and preferably within a _____ of the pump chamber.
50. Any components that need to be accessed or removed from tanks will need to have _____ or disconnect fittings located within _____ of the riser or access lid.
51. Sewerage systems should include access pipes _____ for access to _____ the system.

52. The house to tank sewer is a common cause of system _____, due to _____ or breakage. _____ can also leak into defective collection sewers, overloading the system.
53. Effluent filters should be used in septic (trash) tanks _____, unless the manufacturer _____ they not be used.
54. Ideally, drain the tank area if there is a risk of _____ conditions.
55. All tanks _____ vented. If the tank cannot vent back to the _____, then _____ that meets Volume II standards.
56. Do not increase the cover depth _____ in very cold climate conditions. Limit the depth of cover to _____ even in very cold climate conditions.
57. Check the soil moisture at the surface, and at 20 cm depth. Postpone the installation if a soil grab sample can be _____ ... also, postpone work if squeezing a grab sample of soil _____. Both of these tests indicate that the soil is _____.
58. In a Seepage Bed, the distribution laterals should be _____ across the width of the bed.
59. The standards also provide two specific technologies for at grade systems which are placed directly on native soil and which _____: The _____ and the Alberta At Grade system.
60. An at-grade bed is _____. An aggregate bed placed on contour on the scarified _____. Effluent is distributed to this bed by pressure. The technique is intended for use with pressure distribution only. On a sloping site the bed is _____, the bed follows the ground slope. See Figure III- 20 and Figure III- 21. If the bed is levelled on a sloping site by excavation or adding sand media, then follow the _____.

61. Narrow at-grade beds may be used with a single lateral, with 60 cm orifice spacing along the lateral. For wider beds, use a _____ and low slope sites, and maximum _____ sites.
62. These valves (*hydraulic distributing valves*) should be installed at the _____ of the distribution network, or check valves should be used to prevent _____ on the valve. Ensure the force main to the valve remains _____ causing erratic operation of the valve. An _____ may be used to improve drainage of the valve and filling of the force main.
63. For work on the sand mound, use only _____ with maximum 7 psi ground pressure. Keep a minimum of _____.
64. If an aggregate bed or other gravity distribution system is used to distribute treated effluent from the CTDS to native soil (or native soil with a blinding layer), the bed is considered as a seepage bed or trench (depending on width) and _____, including site capability and _____ aggregate specifications and a maximum trench or bed length of 15 m (measured from the centerline of the CTDS unit along the bed or trench).
 _____ is calculated based on the
 _____ as for Seepage Beds.
65. When constructing the lagoon it is important to observe soil and groundwater conditions. If a _____ or other _____ is seen, investigate and consider relocating the lagoon. This is to avoid risk of the _____ to the layer and also to avoid risk of groundwater entering the lagoon and over filling it.